

**To:** Gardner, Patricia[Patricia.Gardner@dep.nj.gov]; Ash, Christine[Ash.Christine@epa.gov]; Zalaskus, Diane[Diane.Zalaskus@dep.nj.gov]  
**Cc:** Pabst, Douglas[Pabst.Douglas@epa.gov]; Rasso, Mark[Rasso.Mark@epa.gov]; DAgostino, Daniel[DAgostino.Daniel@epa.gov]  
**From:** Burkhard, Kathleen  
**Sent:** Thur 5/24/2018 4:30:44 PM  
**Subject:** RE: Newark Lead Monitoring

Pat is correct, Newark is required to monitor for lead and copper every 6-months, current monitoring period of January – June 2018.

Kathleen Burkhard  
NJDEP – Bureau of Water System Engineering  
609-292-2957

---

**From:** Gardner, Patricia  
**Sent:** Thursday, May 24, 2018 12:08 PM  
**To:** Ash, Christine <Ash.Christine@epa.gov>; Burkhard, Kathleen <Kathleen.Burkhard@dep.nj.gov>; Zalaskus, Diane <Diane.Zalaskus@dep.nj.gov>  
**Cc:** Pabst, Douglas <Pabst.Douglas@epa.gov>; Rasso, Mark <Rasso.Mark@epa.gov>; DAgostino, Daniel <DAgostino.Daniel@epa.gov>  
**Subject:** RE: Newark Lead Monitoring

Christine,  
Newark Water Dept. is collecting lead and copper samples on a 6-month monitoring schedule. I am copying Kat Burkhard to verify my answers in case there are any changes since we last discussed. If you look in DWW – you can see where they are with this monitoring period (Jan – June 2018).

Regards,  
Pat

---

**From:** Ash, Christine [<mailto:Ash.Christine@epa.gov>]  
**Sent:** Thursday, May 24, 2018 10:53 AM  
**To:** Gardner, Patricia <Patricia.Gardner@dep.nj.gov>  
**Cc:** Pabst, Douglas <Pabst.Douglas@epa.gov>; Rasso, Mark <Rasso.Mark@epa.gov>; DAgostino, Daniel <DAgostino.Daniel@epa.gov>  
**Subject:** Newark Lead Monitoring

Hi Pat –

In follow-up to the 5/2/18 call on lead in the Newark water system – I wanted to check in if the Newark water system conducted sampling, or has sampling been scheduled? Is the Newark system on a 6-month monitoring schedule, per the LCR, or has NJDEP made a different determination?

Please let me know if you have any questions. I missed the 5/2 call due to jury duty, so I apologize if this was discussed previously, but any updates you have will be most appreciated.

Thank you!

**Christine Ash**  
Chief, Drinking Water and Ground Water Protection Section  
EPA Region 2  
290 Broadway  
New York, NY 10007  
[ash.christine@epa.gov](mailto:ash.christine@epa.gov)  
(212) 637-4006